# SAA
### A P P R O V A L S ®

## Certificate of Suitability

| | |
|---|---|
| **Certificate No.:** | **SAA221964** |
| Certificate Holder: | Plusrite Australia Pty Ltd<br>Unit 5/13 Gateway Drive<br>Carrum Downs   VIC   3201<br>Australia |
| Regulatory Definition: | Non-Prescribed |
| Product Description: | EV Charger |
| Standard/s: | IEC 61851-1 Ed. 3.0 |
| Condition/s: | Nil |
| Approval Marks: | RCM (In accordance with AS/NZS 4417 and EESS requirements)<br>and<br>SAA221964 |
| Initial Issue Date: | 13 April 2023 |
| Expiry Date: | 13 April 2028 |

For and on Behalf of
**SAA Approvals Pty Ltd**

This certificate is issued by SAA Approvals Pty Ltd in
accordance with the SAA Approvals Electrical Product Safety
Certification Scheme accredited by JAS-ANZ under AS/NZS
ISO/IEC 17065 and RECS accreditation under the Queensland
Government legislative requirements. SAA certifies the
product nominated in this certificate complies with standard/s
listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

**JAS-ANZ**
www.jas-anz.org/register

SAA Approvals
**CERTIFIED**

# Certificate of Suitability

| Model | Trade Name | Rating/ Marking |
|---|---|---|
| EV7.4KW/DLB/T2 | Plusrite Australia | 230Vac 50/60Hz 7.4kW<br>Rated current: 32A (at -25°C ~ 55°C)<br>IP65, Class I |
| EV22KW/DLB/T2 | Plusrite Australia | 400Vac 50/60Hz 22kW<br>Rated current: 32A (at -25°C ~ 55°C)<br>IP65, Class I |
| EV7.4KW/DLB/T2/S | Plusrite Australia | 230Vac 50/60Hz 7.4kW<br>Rated current: 32A (at -25°C ~ 55°C)<br>IP55, Class I |
| EV22KW/DLB/T2/S | Plusrite Australia | 400Vac 50/60Hz 22kW<br>Rated current: 32A (at -25°C ~ 55°C)<br>IP55, Class I |

For and on Behalf of
**SAA Approvals Pty Ltd**

**JAS-ANZ**

www.jas-anz.org/register

SAA Approvals
CERTIFIED